



**ASSA ABLOY**

## **Rectification Report**

---

**Building:** Building XYZ

**Address:** 123 Sample St

**Suburb:** Sampleton

**Date:** 04/05/2022

**Inspection ID:** 5274

Sample

**Touchwood Doors - Rectification Report**

Building XYZ

2/2

No.	Location	Tag	Brand	Dimensions/FRL	Lockset	Closer	Compliant
FD5	L8 Fire Stair		Inglis	2105x840x37			Y
FD14	Ground Floor Fire Stair	5384	Thermador/Masterbilt	2300x1825x45xx1020		Penlux	Y
SD17	Side Reception			2200x940x37			Y
SD17	Side Reception			2200x940x37			Y

Sample

This is a rectification report to QDC, MP 6.1 and A.S. 1851 (2012) on work carried out to the doors listed above. It does not certify that the building is compliant. Smoke doors listed on this report are inspected to BCA requirements as per Specification C3.4.

Work Completed Date: